

GPSC

Water Efficiency Management Programs 2024



Content: GPSC Water Efficiency Management Programs 2024

No.	Content	Page
1.	Introduction	3-4
2.	Water use assessment to identify opportunities for water efficiency improvements	5-9
3.	Actions to reduce water consumption	10
4.	Actions to improve wastewater quality	11
5.	Establishment of targets to reduce water use	12
6.	Application of water recycling	13
7.	Awareness training provided to employees on water efficiency management programs	14




Introduction

Water is essential to develop and maintain successful and healthy economies and for human health and well-being. through the GPSC Water Efficiency Management Program, various processes for water management are conducted, including identification of opportunities to continually improve water efficiency performance, water use review, water use indicators measurement and monitor, and reduction or reuse of water in operations, etc.

In addition, GPSC provides training on the Water Efficiency Management Program to all employee and engagement with external stakeholder to raise awareness on water as the essential for all activities and life.




Introduction



Water use assessment to identify opportunities for water efficiency improvements

Actions to reduce water consumption, Application of water recycling

Establishment of targets to reduce water use



In order to ensure the constructive water management, GPSC has established governance structure and system from the top executives to operation level as well as well defined water strategy, target, and action plan which not only covers the use of water in all activities but also expands to the opportunities of water business to secure company resilience in the future term as well as appoints the functional team lead to responsible in the task and defines the reporting line to follow up each progression in timely basis.

With focusing on water efficiency improvement, the processes including plant water mess balancing, efficiency and loss identification, and water conservation program to 3Rs (reduce, reuse, recycle) are implemented to maximize the water efficiency.

Water use assessment to identify opportunities for water efficiency improvements

GPSC systematically monitors the use of water inside the organization. It is a process to identify activities and functions which have significant use of water and impact on water quality. The activities and functions will be considered as potential for water efficiency improvement.

INPUT	ACTIVITY	WASTEWATER GENERATED	ASSESSMENT APPROACH
Water from outside suppliers	<ul style="list-style-type: none">• Cooling process• Steam production process• Mineral water production system• Condensate water quality improvement unit	<ul style="list-style-type: none">• Sea water through a "Once through cooling system"• Wastewater from production processes	<ul style="list-style-type: none">• Seawater temperature checking in the cooling system prior to releasing this back into the sea. The GPSC group has installed a seawater temperature measurement device, which will work continuously to constantly display this value in the control room of the power plant. An aquatic breeding project in collaboration with fishery groups and local scholars was also conducted.• Water quality check on a monthly basis in accordance with the measures listed in the EIA and EHIA reports.
Water from natural sources, such as sea water			
Tap water	Office services	<ul style="list-style-type: none">• Graywater and blackwater	<ul style="list-style-type: none">• Preparation of a record regarding the water use and wastewater treatment, by first party on a monthly basis.

Water use assessment to identify opportunities for water efficiency improvements

Water Management within GPSC

GPSC conducts site-level water use assessments under its ISO 14001-certified EMS to identify opportunities for improving water efficiency. These assessments have led to 3Rs initiatives such as condensate reuse, boiler wastewater recovery, and cooling water recycling. A key project resulting from this assessment is the **cooling return line installation at CUP2**, reducing service water consumption by **157,680 m³/year**.

To ensure effective implementation and governance, GPSC has established the **Water Management Working Team**, responsible for setting targets, approving action plans, monitoring progress, and coordinating with internal and external stakeholders.

Additionally, GPSC participates in PTT Group's strategic water planning, including the development of the **Self-Rely / Water Secure Portion indicator**, which promotes long-term water efficiency and reduced dependency on public water sources.

Appointment of the GPSC's Water Management Working Team

GPSC
สำนักงานปิโตรเลียมแห่งประเทศไทย
ที่ COO-011/66
เรื่อง แต่งตั้งคณะกรรมการบริหารจัดการน้ำ

เพื่อให้การดำเนินงานธุรกิจของบริษัท ปิโตรเลียมแห่งประเทศไทย จำกัด (มหาชน) เป็นไปอย่างมีประสิทธิภาพ และยกระดับการบริหารจัดการน้ำให้เป็นระบบ พร้อมที่จะเผชิญกับความท้าทายด้านน้ำอย่างเหมาะสมและยั่งยืน ปิโตรเลียมแห่งประเทศไทย ขอแต่งตั้งคณะกรรมการบริหารจัดการน้ำ โดยมีอำนาจหน้าที่และอำนาจหน้าที่ ดังนี้

ข้อ 1 แต่งตั้งให้พนักงานตามรายชื่อต่อไปนี้ เป็นคณะกรรมการบริหารจัดการน้ำ (คณะทำงาน)

ลำดับ	ชื่อ	ตำแหน่ง
1.1	รองกรรมการผู้จัดการใหญ่ฝ่ายปฏิบัติการ	ประธานคณะทำงาน
1.2	ผู้จัดการฝ่ายอาวุโสฝ่ายวิศวกรรมและปรับปรุงโรงงาน	คณะทำงาน
1.3	ผู้จัดการฝ่ายอาวุโสฝ่ายผลิต โรงงานและการผลิต	คณะทำงาน
1.4	ผู้จัดการปฏิบัติการผลิต CUP1	คณะทำงาน
1.5	ผู้จัดการปฏิบัติการผลิต CUP2	คณะทำงาน
1.6	ผู้จัดการปฏิบัติการผลิต CUP3	คณะทำงาน
1.7	ผู้จัดการปฏิบัติการผลิต P1&P2	คณะทำงาน
1.8	ผู้จัดการปฏิบัติการผลิต P1&P3 (COAL)	คณะทำงาน
1.9	ผู้จัดการปฏิบัติการผลิต GSPP1	คณะทำงาน
1.10	ผู้จัดการปฏิบัติการผลิต SBC	คณะทำงาน
1.11	ผู้จัดการปฏิบัติการผลิต GSECO1	คณะทำงาน
1.12	ผู้จัดการปฏิบัติการผลิต GSP	คณะทำงาน
1.13	ผู้จัดการปฏิบัติการผลิต RDP	คณะทำงาน
1.14	ผู้จัดการส่วนปฏิบัติการเคมี	คณะทำงาน

ข้อ 2 ให้คณะทำงาน มีบทบาทหน้าที่และความรับผิดชอบ ดังนี้

- 1.1 กำหนดแนวทางการดำเนินงานและเป้าหมายในการดำเนินงานเรื่องน้ำ
- 1.2 จัดประชุมคณะทำงานฯ เพื่อชี้แจงวัตถุประสงค์และแนวทางการทำงาน
- 1.3 กำหนดกรอบให้หน่วยงานที่เกี่ยวข้องรับผิดชอบงาน และพิจารณาติดตามการดำเนินงานและให้การสนับสนุนการดำเนินงาน ให้เป็นไปตามแผน และเข้ามามีส่วนร่วมในการดำเนินงาน
- 1.4 กำหนดกรอบการดำเนินงาน ในภาพรวมให้เป็นไปอย่างมีประสิทธิภาพ และเกิดประโยชน์สูงสุดต่อองค์กร
- 1.5 ประสานงานกับหน่วยงานที่เกี่ยวข้องในและนอกองค์กร เพื่อให้การบริหารน้ำเป็นบูรณาการ
- 1.6 รายงานผลการปฏิบัติงานให้ Operation Management Committee (OMC) พิจารณา เพื่อพิจารณาอนุมัติต่อไป

ที่นี้ ให้มีผลบังคับใช้ตั้งแต่วันที่ 28 เมษายน พ.ศ. 2566 เป็นต้นไป

ดีเจ วันที่ 28 เมษายน พ.ศ. 2566
(นายสมิทธิ์ อีกรัตน์)

Powers and Duties

1. Setup the guidelines and goals for the action plan on water management
2. Govern/ approve plans and target as well as following up on operations and providing support to operations, according to the action plan and target set
3. Coordinate with relevant parties both inside and outside the company in order to complete all dimension of water management

Water use assessment to identify opportunities for water efficiency improvements

Example of water use assessment by plants

Example of water efficiency monitoring report
(water consumption per MWh production)

Water use assessment to identify opportunities for water efficiency improvements by plant


Example of water efficiency report
(water consumption per MWh production)

GPSC Water Summary			Oct-23	Nov-23	Dec-23	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24
Power Plant Water Index																	
CUP134 Water Consumption	m3		215,933	245,024	209,833	289,595	207,402	202,927	128,668	146,573	196,800	202,814	123,802	184,318	197,229	228,675	228,227
CUP134 Production	MWheq		237,975	232,099	249,679	253,185	240,461	231,604	267,344	266,488	279,571	294,646	285,271	271,119	240,520	241,639	260,106
CUP134 Water Index	m3/MWheq		0.9074	1.0557	0.8404	1.1438	0.8625	0.8762	0.4813	0.5500	0.7039	0.6883	0.4340	0.6798	0.8200	0.9463	0.8774
CUP2 Water Consumption	m3		126,582	107,964	107,711	106,031	101,473	113,679	110,945	110,646	102,499	103,007	101,749	91,551	99,533	107,173	117,302
CUP2 Production	MWheq		82,375	77,211	80,012	73,274	61,558	74,640	75,582	78,666	76,995	77,418	80,276	74,668	81,151	78,487	80,117
CUP2 Water Index	m3/MWheq		1.5367	1.3983	1.3462	1.4470	1.6484	1.5230	1.4679	1.4065	1.3312	1.3305	1.2675	1.2261	1.2265	1.3655	1.4641
Ph2 Water Consumption	m3		74,759	52,256	61,397	55,913	105,806	109,676	84,850	97,300	78,942	58,321	128,020	121,538	157,587	225,694	227,835
Ph2 Production	MWheq		184,315	142,259	168,195	162,669	150,355	149,189	170,308	168,470	179,470	183,918	186,535	178,760	175,895	159,533	184,055
Ph2 Water Index	m3/MWheq		0.4056	0.3673	0.3650	0.3437	0.7037	0.7351	0.4982	0.5180	0.4391	0.3171	0.6863	0.6799	0.8959	1.4147	1.2379
Ph3 Water Consumption	m3		333,488	318,323	324,348	222,739	227,274	257,199	233,500	230,910	255,730	234,480	184,466	247,468	252,115	241,493	208,879
Ph3 Production	MWheq		592,933	597,363	577,627	638,959	589,935	626,369	610,000	593,370	562,439	562,439	542,601	533,475	547,476	457,800	505,463
Ph3 Water Index	m3/MWheq		0.5624	0.5329	0.5615	0.3486	0.3853	0.4070	0.3759	0.3859	0.4169	0.4169	0.3400	0.4639	0.4605	0.5275	0.4132
GPSP11 Water Consumption	m3		137,574	152,910	187,819	155,979	110,478	162,470	162,470	162,470	172,533	147,352	172,654	171,372	182,465	190,997	184,899
GPSP11 Production	MWheq		110,797	103,167	132,798	110,478	122,833	127,000	127,000	127,000	137,252	141,968	140,512	139,229	141,166	135,120	131,895
GPSP11 Water Index	m3/MWheq		1.2410	1.4822	1.4135	1.1519	0.9055	1.2833	1.2833	1.2833	1.2571	1.0379	1.2287	1.2309	1.2926	1.4135	1.4019
GHECO1 Water Consumption	m3		4,800	3,645	12,703	7,121	48,405	279	55,200	55,137	50,806	52,435	53,587	52,424	54,341	37,442	57,696
GHECO1 Production	MWheq		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
GHECO1 Water Index	m3/MWheq		N/A	N/A	N/A	N/A	0.1351	0.1122	0.1153	0.1127	6.7128	N/A	N/A	0.1260	0.1120	0.0784	0.1857
GIIP Water Consumption	m3		34,811	30,566	2,750	10,729	49,388	85,582	51,306	37,397	101,913	15,819	16,873	2,425	2,136	16,598	4,830
GIIP Production	MWheq		29,222	53,348	3,134	38,104	79,460	37,995	30,522	96,151	11,054	16,696	0	1,317	8,830	16	16
GIIP Water Index	m3/MWheq		1.1913	1.4401	1.3638	3.4235	1.2961	1.0770	1.3503	1.2253	1.0599	1.4310	1.0106	N/A	1.6220	1.8797	307.6433
SRC Water Consumption	m3		12,427	20,572	13,899	17,411	8,970	83,555	217,918	305,654	132,396	1,310	1,200	1,867	-372	10,164	35,265
SRC Production	MWheq		0	0	0	0	0	45,133	147,775	218,445	74,168	0	0	0	0	0	19,363
SRC Water Index	m3/MWheq		N/A	N/A	N/A	N/A	N/A	1.8513	1.4747	1.3992	1.7851	N/A	N/A	N/A	N/A	N/A	1.8212
RDF Water Consumption	m3		5,258	30,268	12,713	35,409	32,427	22,656	21,163	11,274	22,785	21,802	21,802	19,042	17,276	33,153	35,173
RDF Production	MWheq		169	4,260	4,710	5,010	2,143	4,961	3,573	3,908	1,708	4,454	4,398	3,306	2,590	5,509	5,766
RDF Water Index	m3/MWheq		31.0977	7.1055	2.6991	7.0671	7.1590	6.5361	6.3409	5.4157	6.6018	5.1155	4.9574	5.7605	6.6696	6.0176	6.0997
Glow Energy Solar Farm Water Consumption	m3		75	62	75	109	247	159	174	164	95	8	7	17	26	24	15
Glow Energy Solar Farm Production	MWheq		155	182	203	191	202	210	222	159	167	139	178	141	163	190	198
Glow Energy Solar Farm Water Index	m3/MWheq		0.4832	0.3407	0.3703	0.5719	1.2206	0.7569	0.7835	1.0338	0.5698	0.0575	0.0392	0.1206	0.1597	0.1264	0.0758
Total Water Consumption	m3		940,422	931,260	990,503	909,108	895,897	1,078,366	1,047,893	1,160,674	1,105,560	815,537	782,351	872,963	945,034	1,058,236	1,064,934
Total Production	MWheq		1,237,940	1,177,765	1,266,572	1,621,796	1,572,434	1,846,926	1,920,315	2,000,749	1,402,546	1,276,037	1,256,467	1,616,712	1,675,321	1,564,395	1,497,654
Total Water Index	m3/MWheq		0.7597	0.7907	0.7820	0.5606	0.5698	0.5839	0.5457	0.5801	0.7883	0.6391	0.6227	0.5400	0.5641	0.6765	0.7111



Water use assessment to identify opportunities for water efficiency improvements

Example of water use assessment by plants



Water use assessment to identify opportunities for water efficiency improvements

Water Management outside GPSC



Example of GPSC's Representation in PTT Group Water Management Task Force

In addition to site-level water assessments, GPSC also contributes to PTT Group's **strategic water risk management** through the development of the **Self-Rely / Water Secure Portion** indicator in 2024. This metric evaluates the proportion of water sources that are under direct control of the Group, including:

- **Desalinated water from seawater**
- **Water from 3Rs initiatives** (Reduce, Reuse, Recycle)
- **Backup surface water reserves**
- **Groundwater sources**

This indicator is applied in both **normal operations and crisis scenarios**, helping GPSC and PTT Group enhance long-term water security and reduce reliance on public water supply.

ความร่วมมือเตรียมการจัดทะเบียนองค์กรผู้ใช้น้ำของ กลุ่ม ปตท. ในวาระปี 2568-2570

GPSC	GPC	ptt	IRPC	Thonburi
คุณเกรียงศักดิ์ มงคลเจริญทรัพย์ ประธานเจ้าหน้าที่บริหาร กลุ่มบริษัทปิโตรเลียมแห่งประเทศไทย	คุณศิริเมธ ธีการักษ์ ประธานเจ้าหน้าที่บริหาร กลุ่มบริษัทปิโตรเลียมแห่งประเทศไทย	คุณสรวิชัย เลิศศิริกร ผู้อำนวยการบริหาร กลุ่มบริษัทปิโตรเลียมแห่งประเทศไทย	คุณเดวิด คองว่อง รองกรรมการผู้จัดการใหญ่ ปิโตรเลียม	คุณเมฆพร บรรลือศรีเรือง รองกรรมการผู้จัดการใหญ่ ด้านพาณิชย์
GPSC	GPC	ptt	IRPC	Thonburi
Existing	1		1	
New Register	13	12	1	8

Example of GPSC participates in the PTT Group's registered water user organization under the national basin-level governance framework for the 2025–2036 cycle.

Water use assessment to identify opportunities for water efficiency improvements


Water Management outside GPSC

GPSC manages external water by actively participating in the PTT Group Water Management Task Force, which holds meetings on water situations from the survey and analysis of the water situation model, and consequently formulates a water management plan, guidelines for monitoring water management targets, risk reduction, and assessment of impacts of water use in all operating areas. We finally communicate with responsible business units for efficient implementation of plans. The PTT Group Water Management Task Force also participates in the Water Management Working Group of the Eastern Region of Rayong. The working group, made up of governmental agencies and representatives of the private sector, monitors, assesses, analyzes the water situation and maps out measures to promptly reduce risks and impacts.

GPSC also leverages the Aqueduct Water Risk Atlas of the World Resources Institute (WRI) to identify water stress areas and determine the guidelines for the management of water sources outside all operating areas.

The River Basin Committee Structure under the Industrial Sector Group

โครงสร้างคณะกรรมการลุ่มน้ำ: จัดตั้งองค์กรผู้ใช้น้ำเพื่อเลือกผู้แทนอุตสาหกรรมในคณะกรรมการลุ่มน้ำ



Example of GPSC's Representation in Water management Outside GPSC

Actions to reduce water consumption

Following the water use assessment to pinpoint areas for reduction, GPSC prioritizes water management approaches across the operations and offices. This approach includes all measures focused on reducing the amount of water required for business activities and operations regarding equipment, systems or processes at facility/site level to those concerning employees/staff in office functions.

The water management performance of all operations and offices is closely monitored to ensure ongoing effectiveness. The below table shows water management approaches in operations and office services.

INPUT	ACTIVITY	WASTEWATER GENERATED	MANAGEMENT APPROACH
Water from outside suppliers	<ul style="list-style-type: none"> Cooling process Steam production process Mineral water production system Condensate water quality improvement unit 	<ul style="list-style-type: none"> Sea water through a "Once through cooling system" Wastewater from production processes 	<ul style="list-style-type: none"> Regular inspection of the seawater pumping point to ensure the seawater pumping equipment and the aquaculture net to be in good working order. Reuse the effluent from the sludge dewatering system directly. Reuse wastewater (RO Reject) in the industrial water production system. Water from the coal yard and other wastewater are treated and collected in the pond before being recycled to spray onto coal piles to remove coal dust.
Water from natural sources, such as sea water			
Tap water	Office services	<ul style="list-style-type: none"> Graywater and blackwater 	<ul style="list-style-type: none"> 3Rs (Reduce, Reuse, Recycle) Monitor and fix leaks Encouraging and training for water-conscious behavior

Actions to improve wastewater quality

GPSC emphasizes wastewater quality before discharging into water basis to comply with relevant regulations and avoid conflict with stakeholders. There are various measures implemented at facility level to improve the quality of wastewater/discharge water at the source (e.g., process improvements) and to monitor effluent (periodic sampling).

The wastewater quality of all operations and offices is closely monitored. The below table shows water management approaches in operations and office services.

INPUT	ACTIVITY	WASTEWATER GENERATED	MANAGEMENT APPROACH
Water from outside suppliers	<ul style="list-style-type: none">• Cooling process• Steam production process• Mineral water production system• Condensate water quality improvement unit	<ul style="list-style-type: none">• Sea water through a "Once through cooling system"• Wastewater from production processes	<ul style="list-style-type: none">• Install a device to measure the temperature and residual chlorine of sea water after cooling to be careful not to exceed the standard of wastewater from the production process.• Treat to achieve standard values and pass the criteria to then release back into natural water sources.
Water from natural sources, such as sea waste			
Tap water	Office services	<ul style="list-style-type: none">• Graywater and blackwater	<ul style="list-style-type: none">• Install grease traps• Promote employee awareness• Monitor and maintain the wastewater treatment system

Establishment of targets to reduce water use

GPSC has established specific, measurable, and time-bound targets to reduce water use at both the company and plant levels. For example, 5.00% Water Saving of Normal Daily Water Consumption for MTP Area. These targets were derived based on peer benchmarking, operational data, and cost/stakeholder analysis. Progress is monitored quarterly through GPSC's water efficiency dashboard. All targets and progress are integrated into GPSC's environmental KPIs and reported to the Water Management Working Team.

Reduce Water use target by plant

Example of quantified target by plant to reduce water use per production

GPSC Water Index (m3/MWheq Net)									
Plant	2022	2023	2024	2025	KPI(2024)				
	Full Year	Full Year	Full Year	Full Year	Target L1 (+5% of L3)	Target L2	Target L3	Target L4	Target L5 (-5% of L3)
CUP134	0.927	0.712	0.746	0.75	0.835	0.75	0.775	0.756	0.756
CUP2	1.485	1.577	1.386	1.48	1.568	1.5	1.481	1.446	1.409
Glow MTP Ph2	1.009	0.496	0.708	0.73	0.480	0.75	0.719	0.701	0.701
Glow MTP Ph3	0.527	0.500	0.415	0.48	0.615	0.499	0.481	0.469	0.457
Glow SPP11	1.577	1.501	1.237	1.23	1.475	1.494	1.438	1.403	1.366
GHECO1	0.094	0.156	0.134	0.13	0.131	0.131	0.128	0.125	0.122
Glow IPP	1.277	1.286	1.214	1.2	1.322	1.290	1.259	1.227	1.196
SRC	1.076	1.001	1.535	1.5	1.264	1.234	1.204	1.174	1.144
RDF	8.571	7.947	6.075	6.0	7.907	7.719	7.531	7.343	7.154
Glow Energy Solar Farm	0.337	0.432	0.484	0.4	0.439	0.428	0.418	0.407	0.397
Total	0.744	0.748	0.617	0.70	0.738	0.720	0.703	0.685	0.668

Note:
1) Excluded Sea Water Consumption
2) Excluded Water Export to Industrial Customers
3) CUP1 CF import meter read error, so applied 30% addition for correction factor. [Fixed as of Jun 2024]
4) Excluded Water Consumption during EGAT dispatched reserve shutdown for IPP Business.
5) 2025 Target is averaged 2022-2024.

Example of water use assessment by plants

In setting its water efficiency targets, GPSC follows a structured process:

1. Identify high-potential sites where operational characteristics indicate significant opportunities for water reduction.
2. Set quantifiable targets for each selected site, aligned with industry benchmarks and GPSC's long-term water strategy.
3. Monitor monthly progress through a digital dashboard and site-level performance reports, with oversight by the Water Management Working Team. This process ensures that water reduction efforts are data-driven, prioritized, and continually improved over time.

GPSC Group Water 3R Program																				
			Normal Daily Water Consumption for MTP Area			m3/d												68,354		
			5.00% Water Saving of Normal Daily Water Consumption for MTP Area			m3/d												3,418		
			10.00% Water Saving of Normal Daily Water Consumption for MTP Area			m3/d												6,835		
							2024													
Item No.	ID	Area	Plant	Project	Eng. Unit	Project Stage	Remark	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Water Saving per Day	Water Saving per Month	Water Saving per Year			
					Day	L1-L5		31	29	31	30	31	30	31						
				Total Actual				592,124	559,764	600,085	583,614	627,995	685,545	682,940	7,965	238,944	2,883,297			
				Total Actual				296,062	275,882	300,042	291,807	313,998	342,772	341,470	7,420	222,613	2,685,702			
				Water Saving of Normal Daily Water Consumption for All Area																
				0.86% Water Saving of Normal Daily Water Consumption for MTP Area																
1	WR-CU1-24-01	MTP	CUP1	reduce steam denox 10% by increase ammonia injection instead (Based on 2*4=8 m3/h)	m3	L5									189	5,681	69,120			
2	WR-CU1-24-02	MTP	CUP1	reduce continuous blow down 90% by increase chemical feed instead (Based on 2*6=12 m3/h)	m3	L5											5,113			
3	WR-CU1-24-03	MTP	CUP1	reduce cooling blow down 50% by increase chemical feed instead (Based on 2.12 m3/h)	m3	L5											753			
4	WR-CU1-24-04	MTP	CUP1	recycle sampling TOC to cooling basin	m3	L5											162			
5	WR-CU1-24-05	MTP	CUP1	in RO-After Mix Bed for reducing TOC<300ppb for AVT by reusing RO-water reject 100% assume 2*2 train=60m3/h	m3	L5	Start as of Jul 24								1,420	42,608	518,400			
6	WR-CU2-24-06	MTP	CUP2	coling Blowdown to Water Spray Blowdown Tank	m3	L5	Project Phase1 and Phase2	14,400	14,880	14,400	14,880	14,880	14,400	14,880	463	13,894	166,730			
7	WR-CU2-24-07	MTP	CUP2	FESQ Improved Demin Water throughput of Mixed Bed	m3	L5		639	658	660	413	715	509	654	19	564	6,771			
8	WR-CU2-24-08	MTP	CUP2	recovery Cleaning Water from Sludge Disposal by Improvement Filter Press System	m3	L5		20	42	19	35	29	30	22	1	28	337			
9	WR-CU2-24-09	MTP	CUP2		m3	L5						4,821	4,666	4,821	159	4,769	57,232			
10	WR-CU2-24-10	MTP	CUP2		m3	L5	Synergy project just reduce to 7 m3/hr, so no information from 7 to 6								96	2,880	35,040			
11	WR-CU2-24-11	MTP	CUP2	reduce 24HRSG Continuous Blowdown from 2 t/h to 1 t/h	m3	L5									48	1,440	17,520			
12	WR-CU2-24-12	MTP	CUP2	reduce AB21 Continuous Blowdown from 1 t/h to 0.5 t/h	m3	L5									12	360	4,380			
13	WR-CU2-24-13	MTP	CUP2	new Brine-RO, Water saving 10 m3/hr	m3	L4	Usage water from Holding pond 20 m3/hr, supply to new Brine-RO project and get to RO permeate 10								240	7,200	87,600			
14	WR-CU3-24-14	MTP	CUP3	increase STG31 Cooling Flow with Saving Water 15.073 m3/h when run low load	m3	L5						6,971	6,662	6,971	268	8,662	105,632			
15	WR-CU3-24-15	MTP	CUP3	increase cycle MIXED POLISHER	m3	L5									8	247	2,961			
16	WR-CU3-24-16	MTP	CUP3	UP3 Saving kilowatt of Cooling tower unit (STG-31)	m3	L5									60	1,799	21,583			
17	WR-CU4-24-17	MTP	CUP4	Saving Service Water during Test Running Fire Water Pump	m3	L5		1,796	1,796	2,245	1,796	1,796	2,245	1,796	65	1,942	23,306			
18	WR-CU4-24-18	MTP	CUP4	Just Angle of Cooling Fan	m3	L5		79	74	79	77	79	66	79	19	559	6,706			
19	WR-CU4-24-19	MTP	CUP4	se Retention Water for Watering Plants	m3	L5		360	360	360	180	360	390	390	13	378	4,537			
20	WR-CU4-24-20	MTP	CUP4	reduce Blowdown Water of HRSG and Save CF Quenching	m3	L5		8,620	8,998	8,620	8,310	8,620	7,448	8,620	274	8,217	98,605			

Application of water recycling

Water Recycling Initiative: Cooling Return Line Installation for Main Steam Blowdown Tank

Project Name: *Install Line Cooling Return for Water Spray – Main Blowdown Tank (Efficiency Uplift)*

Location: Central Utility Plant 2 (CUP2), GPSC

Objective:

To reduce the use of service water by redirecting **cooling water return** to lower the temperature of the **main steam blowdown tank** prior to discharge into the underground sump pit. This initiative enhances **water efficiency**, **reduces freshwater dependency**, and supports **GPSC's water crisis mitigation program**.


Action Taken:

A new pipeline was installed to **tie in cooling water return** in place of service water for temperature control at the blowdown tank. The system was applied across three areas:

- Main blowdown: 5 m³/h saving
- AB21 blowdown: 3 m³/h saving
- HRSG blowdown: 10 m³/h saving

Project Highlights (CUP2) :

- **Water Saved:** 18 m³/hour → 157,680 m³/year
- **Electricity Saved:** 0.589 kW → THB 22,659/year
- **Total Cost Savings:** THB 3.48 million/year
- **CO₂ Reduction:** 1,017 kg/year
- **Investment Cost:** THB 1.3 million
- **Payback Period:** 0.4 years



Example of Cooling Water Return System and Blowdown Tank Configuration at CUP2

Awareness training provided to employees on water efficiency management programs

In 2024, GPSC promoted employee awareness on water efficiency through both online and on-site knowledge-sharing events.

In May, GPSC joined the “One on One Online Sharing: Strengthen Water Efficiency,” where GC experts provided technical knowledge on increasing cooling water cycles and reducing blowdown through advanced water chemistry controls.



Additionally, in September, GPSC employees participated in the “CoP #1/2567: Cooling Tower Optimization and Recent Technology” held on-site at NPC S&E in Rayong. The event featured industry experts and cooling tower solution providers who shared best practices and recent innovations in optimizing cooling tower performance, reducing energy use, and minimizing water loss.

These programs strengthen GPSC’s technical capacity and promote the practical implementation of water-saving solutions across operations, in alignment with the company’s water efficiency strategy.

THANK YOU

